

- Device name: **JT-60SA**
- Native data format/data access library:
  - Software provided by external IT company, access via Fortran library
  - Most people use a python wrapper
- Contact persons (name + email) for IMAS / Data mapping:
  - Official IMAS IT position (RO?) recently established at QST
  - Antti Jokinen(working at QST [F4E]) Antti.Jokinen@f4e.europa.eu
  - assisting from ITER are Simon McIntosh & Francesca Poli
- List of IDS with mapped data (+ DD version):
  - in works are
    - Soft-X ray SXR
    - Interferometry CO2
    - Equilibrium & Wall
- How the mapping is done (manually, via tools/scripts, hard-coded vs mapping file...):
  - Working on scripted processing
  - List of needed IDS entries for IDA was compiled (see “appendix” on next pages)
- Pulses (or ranges of) being mapped:
  - For IDA E101008
- Applications that are using the mapped IMAS data:
  - IDA
  - TOKOMTOK (Tomography)
  - potentially ASCOT and JINTRAC
- Data access policy (contact + collaboration + possibility to share test data):
  - no raw data access for non-QST personell. Access effectively through RO.
- Plans over the coming year:
  - Install IMAS centrally (as opposed to installation in user folder)
  - map available (preprocessed) data
  - produce IDSs useful for QST
  - ... and hope for relaxation of restrictions.

## IDS entries required for IDA

### **Equilibrium**

equilibrium\_ids/time\_slice/profiles\_2d/r  
equilibrium\_ids/time\_slice/profiles\_2d/z  
equilibrium\_ids/time\_slice/global\_quantities/psi\_axis  
equilibrium\_ids/time\_slice/global\_quantities/psi\_boundary  
equilibrium\_ids/time\_slice/profiles\_2d/psi

### **interferometer CO2**

interferometer\_ids/channel[i]/line\_of\_sight/first\_point/r  
interferometer\_ids/channel[i]/line\_of\_sight/first\_point/z  
interferometer\_ids/channel[i]/line\_of\_sight/first\_point/phi  
interferometer\_ids/channel[i]/line\_of\_sight/second\_point/r  
interferometer\_ids/channel[i]/line\_of\_sight/second\_point/z  
interferometer\_ids/channel[i]/line\_of\_sight/second\_point/phi  
interferometer\_ids/channel[i]/wavelength[0]/value  
interferometer\_ids/time  
interferometer\_ids/channel[i]/n\_e\_line  
interferometer\_ids/channel[i]/n\_e\_line\_average

Note that only one of the two is needed: n\_e\_line or n\_e\_line\_average and for the \_average the length assumed for the calculation.

### **soft\_x\_ray SXR (skipping the sxr\_ids/channel prefix)**

name  
etendue  
line\_of\_sight (like with interferometry with first and second)  
filter\_window  
energy\_band  
power and/or brightness

open topic → aperture (modelling measurement with several rays per LOS etc)

### **spectrometer\_visible VIS (again skipping prefix)**

detector\_layout  
channel/name  
channel/type  
channel/aperture  
channel/etendue  
channel/etendue\_method  
channel/los\_of\_sight  
channel/detector\_image (I guess)  
channel/fibre\_image (diagnostician would have to comment if applicable)  
channel/light\_collection\_efficiencies  
channel/active\_spatial\_resolution  
channel/polarizer  
channel/filter\_spectrometer